



BEARING AREAS EACH DIRECTION OF THRUST IN SQUARE FEET				
PIPE SIZE	TEES & DEADENDS	90° ELBOWS	45° ELBOW CROSSES IN DIRECTION OF FLOW	22-1/2° ELBOWS
6"	4.0	5.5	3.0	2.0
8"	7.0	9.5	5.0	3.0
10"	9.5	13.5	7.0	4.0
12"	13.5	19.0	10.0	5.0
14"	18.0	23.5	14.0	7.0
16"	23.0	33.0	18.0	9.0

REVISIONS				<b>CITY OF LAKEPORT</b>		<b>THRUST BLOCK DETAIL</b>		SCALE: N.T.S	
Description	By	Approved	Date	Drawn By:	SMH			Checked By:	MB
				Approved:	5/2005				