



SIZE OF METER	DIMENSION	
	A	B
5/8" x 3/4"	10"	12"-14"
1"	10"	12"-14"

NOTES

1. Service lateral bedding material to be compacted to minimum 90% relative compaction prior to installation of poly service tubing.
2. Unless otherwise specified on the plans, provide for 5/8" x 3/4" meter installation for residential uses and 1" meter installation for commercial uses.
3. Unless otherwise specified on the plans, install 3/4" service tubing for residential uses and 1" service tubing for commercial uses.
4. The City of Lakeport requires a minimum of 10 ft of separation between potable water and sewer lines.
5. Meter box must be set flush with top of curb or sidewalk, if applicable.
6. Prior to meter set, address to be clearly marked on topside lip of meter box with permanent felt marker.
7. For 5/8" x 3/4" meter installation on a 1" water service lateral, use a reducing adapter.
8. Traffic lid to be installed in all drive approaches and locations where vehicular traffic may occur, and where specified on plans.

METER SETTING ASSEMBLY PARTS LIST

METER SIZE	Angle Meter Stop	Hand Valve
5/8" x 3/4"	Ford BA43-332W or equal	Ford B13-332W or equal, w/handle
1"	Ford BA43-444W or equal	Ford B13-444W or equal, w/handle

METER BOXES AND COVERS

- 3/4" Christy B9X Box, with B9XD or B9X61D (traffic) cover.
- 1" Christy B12 Box, with B12D or B1261D (traffic) cover.

<i>City of Lakeport</i>		
3/4" & 1" WATER SERVICE LATERAL FOR 5/8" x 3/4" & 1" METERS		
SCALE: NONE	DATE: March 04	
DWN: CHK:	APPROVED PH-MEB-MKS	FILE NO.